

**BIG RAPIDS TOWNSHIP BUILDING DEPARTMENT  
AFFIDAVIT OF GAS LINE TEST**

Date: Mechanical Permit No.

Property Owner's Name:

Contractor and/or Company Name:

On the above date, a gas pipe system air test was conducted on the

**CONCEALED PIPING**

and was tested at a minimum of 3 lbs/sq.in. for 10 minutes (according to the procedures set forth in the International Mechanical Code of 1996) by:

Agent Name:

signature

Witnessed by:

signature

Mechanical Inspector:

On the above date, a gas pipe system air test was conducted on the

**EXPOSED PIPING**

and was tested at a minimum of 3 lbs/sq.in. for 10 minutes (according to the procedures set forth in the International Mechanical Code of 1996) by:

Agent Name:

signature

Witnessed by:

signature

Mechanical Inspector: